

PROFORMA - SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

CERTIFICATE NO-

DATED-

It is certified that an inspection team headed by **Assistant Engineer, Shashank Pandey** from **U.P. Jal Nigam Gorakhpur** inspected the, **S R International Academy, Gajpur, Banspar, Gorakhpur** on **23/12/2025** and on the basis of Water Test Report (Attached) bearing no **182/camp/lab-1** dated **29/12/2025** of District Water Analysis Laboratory Jal Nigam Gorakhpur (PHED Lab) certified that the **S R International Academy, Gajpur, Banspar, Gorakhpur** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Govt.

The above valid for a period of 29/12/2025 to 28/12/2026

Ramberu

Signature With Seal :-


Assistant Engineer
10th Division, U.P. Jal Nigam
GORAKHPUR

Name :- Shashank Pandey

Designation:- Assistant Engineer

To,

Manager

S R International Academy,

Gajpur, Banspar, Gorakhpur(273413)



District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Gorakhpur

Address: EWS 388,389,390 Rapti Nagar Phase-I, Medical Road,
Gorakhpur(U.P)-273003



TC-16928

CHEMICAL SAMPLE TEST REPORT

Rept. No 182 /Camp / Lab-1 Date: 29/12/2025 Page No 1/1

Customer Details

Office Name and Address S.R International Academy, Gajpur, Banspar, Gorakhpur
Ref Letter No & Date 18/12/2025

Basic details of sample

District	Gorakhpur	Block	Kauriram
Gram Panchayat	Gajpur	Village	Gajpur
Habitation	--	Location	S.R International Academy, Gajpur, Banspar, Gorakhpur
Water Source	R.O	Sample Code	(C/25/12/16)
Quantity of Sample	1000 ml	Date of S.C.	23/12/2025
Receiving Date	23/12/2025	S. Collector	Rambabu
Sample Depositor	Rambabu		
Analysis Start Date	24/12/2025	Analysis Completion Date	24/12/2025

Environmental Condition

Temperature	24.6°C	Relative Humidity	52%
-------------	--------	-------------------	-----

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Odour	Agreeable		Agreeable	Agreeable	IS 3025 (Part 5):2018
2	Turbidity	0.22	NTU	1	5	IS 3025 (Part 10):2023
3	pH (25°C)	7.20	--	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
4	Total Dissolved Solids	80	mg/L	500	2000	IS 3025 (Part 16) :2023
5	Total Hardness	52	mg/L	200	600	IS 3025 (part 21) :2023
6	Total alkalinity	62	mg/L	200	600	IS 3025(Part 23):2023
7	Chloride as Cl ⁻	16	mg/L	250	1000	IS 3025(Part 32):2003
8	Calcium	12.8	mg/L	75	200	IS 3025(Part 40): 2024
9	Magnesium	4.87	mg/L	30	100	IS 3025(Part 46): 2023
10	Sulphate	1.549	mg/L	200	400	APHA 24th Edition 4500-SO ₄ Method E Turbidimetric Method 2023
11	Nitrate	0.209	mg/L	45	No relaxation	APHA 24th Edition 4500-NO ₃ Method B UV Screening Method 2023
12	Iron	0.032	mg/L	1	No relaxation	APHA 24th Edition 3500-Fe Method B Phenanthroline Methods 2023
13	Fluoride	0.067	mg/L	1.0	1.5	APHA 24th Edition 4500-F Method C (Electrode Method) :202300
14	Arsenic	BDL	mg/L	0.01	No Relaxation	APHA 24th Edition 3500 Method B (Silver Diethyldithiocarbamate Method)

#BDL- Below Detection Limit, NA- Not Analyzed

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non - perishable items only) from the date of issue of tests reports unless.
 5. Sample collected by the laboratory.

Vishal Mondal
Review By

B. Pandey
Authorized Signatory
10th Division, U.P. Jal Nigam
GORAKHPUR

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact : +91 8604561988

-----End of Report-----



District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Gorakhpur

Address: EWS 388,389,390 Rapti Nagar Phase-1, Medical Road, Gorakhpur(U.P)-273003

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	182 /Camp / Lab-1	Date:	29/12/2025	Page No	1/1	
Customer Details						
Office Name and Address	S.R International Academy, Gajpur, Banspar, Gorakhpur					
Ref Letter No & Date	18/12/2025					
Basic details of sample						
District	Gorakhpur	Block	Kauriram			
Gram Panchayat	Gajpur	Village	Gajpur			
Habitation	--	Location	S.R International Academy, Gajpur, Banspar, Gorakhpur			
Water Source	R.O	Sample Code	(C/25/12/16)			
Quantity of Sample	500 ml	Date of S.C.	23/12/2025			
Receiving Date	23/12/2025	S. Collector	Rambabu			
Sample Depositor	Rambabu					
Analysis Start Date	23/12/2025	Analysis Completion Date	26/12/2025			
Technical Data of Analysis						
Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH (25°C ± 2°C)	7.20		6.5-8.5	No relaxation	IS 3025 (Part 11):2017
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025 (PART 26) : 1986
3	Total Coliform	0	CFU	0	CFU	APHA 23 rd Edition :2017
4	E .Coli	0	CFU	0	CFU	APHA 23 rd Edition :2017
Result : Satisfactory						Remark: Potable
Note 1. This Certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of tests reports unless.						
Analysed By			Authorized Signatory			
Laboratory Contact details: Email-labgorakhpur@gmail.com			Contact - +91-8604561988			

-----End of the Report-----